

**Issued: 6/21/18**

**Clarification No. 1**  
**Bid 17/18-30, Omega Park Improvements**

**DUE DATE: Monday, June 25, 2018, 4:00 pm**

**OPEN DATE: Tuesday, June 26, 2018, 1:00 pm**

The following clarifications are for the above bid number and title:

1. Note #3 on A401 calls for 8" nominal painted block. All drawings including elevations and wall sections and details show regular block? Verify that concrete masonry units are to be painted and not split-faced.

[Response: Concrete masonry units Typical \(Painted\) is correct.](#)